

## 2026 First Quarter

### DWQMS Report to Council

The purpose of this report is to summarize for Town Council the activities relating to the Public Works – **Water Distribution System** for the period of January 2026 through March 2026.

#### MECP Drinking Water Inspection

The Ministry of Environment, Conservation, and Parks (MECP) completed an inspection of the drinking water system (both treatment and distribution) on January 14, 2026. Staff are pleased to announce there were no findings during this inspection period and no recommendations. The Town of Carleton Place once again received a rating of 100%.

#### Operational Plan Revisions

The following revisions were made to the Operational Plan during this period.

- Essential Supplies and Services List Updated

#### Drinking Water Quality

To date in 2025, there have been three (3) calls by residents concerning water quality. They are summarized as follows:

- 2 - Noise / Service Issues
- 1 - Taste / Odour
- 0 – Visual
- 0 – Watermain Break
- 0 - Other

#### Operational Activities

During the period January through March, the Waterworks team completed the following activities:

- Oversaw watermain connections at Water Plant
- Oversaw watermain connections – Taber Street fourplex
- Thawed multiple water services
- Repaired water service – 255 Lake Avenue E
- Disconnected water service – 66 Moore Street – pending development
- Continued locates
- Completed quarterly meter reads
- Undertook monthly hydrant flushing

#### Consumption Statistics (Raw Water)

	JAN	FEB	MAR
Max.	7332.94	7525.36	6831.38
Mean	5941.97	6003.15	5925.48
Min	5196.51	5045.26	5382.41

Total	184201.05	168088.27	183689.77
-------	-----------	-----------	-----------

Same Period in 2025: 623264.6 m<sup>3</sup>  
Total for this Quarter: 535979.1 m<sup>3</sup>  
Difference: 87285.5 m<sup>3</sup> or 14% decrease